

From:Jonathan Lloyd
Sent:23 Oct 2018 15:38:04 +0100
To:George Burrell
Subject:Fire Authority representation The Hangar Pountney Street Wolverhampton
Attachments:wmfs application guidance version 2 updated Nov 2011.doc

Sensitivity: PROTECT

From: Neil Aston-Baugh <[REDACTED]>
Sent: 11 October 2018 09:39
To: Licensing <Licensing@wolverhampton.gov.uk>
Cc: Rob Edge. Licence Leader Ltd <[REDACTED]>
Subject: Fire Authority representation The Hangar Pountney Street Wolverhampton

I refer to the application for a premises licence for the above premises.

Currently there is insufficient information within the application to demonstrate that the public safety objective will be adequately promoted.

Plans should identify locations of fire safety equipment, systems and components , relevant dimensions, and suitable provision of means of escape from the premises.

The current means of escape from the premises appears to rely on the use of roller shutter doors which the Fire Authority does not consider to be a suitable or safe provision for members of the public.

There is mention of disabled refuges which are not shown on the plan. A Disabled refuge requires particular provisions such as fire protection and should be designed in accordance with the building regulations or BS9999.

The premises will also require a building regulations application to ensure that it is safely designed.

Due to the reasons set out above, The Fire Authority hereby makes representation to the application.

I have attached some additional guidance to assist the applicant with submission of a suitable application and will be consulting with the applicant to assist them further.

The representation will not be withdrawn until the Fire Authority is satisfied that the Public Safety Objective will be adequately promoted in respect of the application.

Should you require any further information or clarification of my decision, please do not hesitate to contact me.

Regards

Neil Aston-Baugh

[Redacted]

[Redacted]

[Redacted]

[Redacted]

[Redacted]

[Redacted]

[Redacted]