## WEST MIDLANDS FIRE SERVICE

## **Note for Case**

Property No.

**Relevant Legislation** 

7	M	3	7	8	5	Z	В	

## The Malt Shovel, 131 Willenhall Road, Wolverhampton. WS1 2HR

I was asked by the licensee and the Police to visit the premises to assess the capacities of the two rooms of the pub. A prohibition notice had been served on the premises restricting the numbers to 60 in each room. The doors on the lounge have now been changed to out ward opening in stead of inward as they did before. My self and S.C. Mair discussed to great length the fire safety issues and have amended the prohibition notice to read lounge 80 and the bar 60 maximum occupancy at any time. The old one has been uplifted and the new served with the police, data management and the licensing authority notified. Mr Eucal Shippey the licensee has been informed and strict control of the numbers and the door staffing must be carried, with good maintenance of the fire safety procedures adopted.

The Regulatory Reform (Fire Safety) Order 2005

**Supervisory Officer** 

10/4/2014	Signature	
		SHAUN MESSER