


**NAME OF PREMISES:** Harp Inn

**ADDRESS:** Walsall street  
Wolverhampton WV1 3LP

**Voluntary undertaking- Supplement to Application**

*Before signing this document, you should be aware that failure to comply with this undertaking may result in a review of the premises licence and/or enforcement action under the Regulatory Reform (Fire Safety) Order 2005*

PUBLIC SAFETY
<p>1) A fire alarm system will be provided to cover the whole of the building and will comply with BS5839, Part 1 2017</p> <ul style="list-style-type: none"> <li>• It will incorporate a cut out device which silences any amplified music upon actuation</li> <li>• Break glass call point are not required on final exits from public areas but will be provided in other appropriate areas.</li> <li>• Suitable automatic detection will be provided including a heat detector in the kitchen</li> </ul> <p>The premises will not open to members of the public until the system is fitted and the Fire Officer has approved the certificate for the system1</p>
<p>2) The fire door at the base of the staircase will be provided with an intumescent strip, smoke seal and self-closing device, prior to the premises opening to members of the public</p>
<p>3) The kitchen will be provided with a suitable fire door prior to the premise opening to members of the public</p>

APPLICANT'S SIGNATURE  .....  
(Authorised on behalf of the Premises Licence Holder/applicant)

DATE 19/2/19 .....

AUTHORISED OFFICER...Neil Aston-Baugh  
(POSITION)...Fire Safety Inspecting Officer  
(Authorised on behalf of West Midlands Fire Authority)