

## FILE NOTE

---

From; Emma L Waites - SEHO  
Environmental Health Commercial  
Tel. 07584 175352

To; Premises Licence Applicant  
cc; Debra Craner - Licensing

Date: 28.4.20

### Mediation Outcome -

A dialogue was held on the 28.4.20 with the applicant which discussed the Environmental Health Sections representations relating to the Prevention of Public Nuisance in its capacity as a Responsible Authority.

### Public Nuisance

In relation to Public Nuisance it was agreed that the following conditions would be added to the Premises Licence:

1. Prior to the Rose Banqueting Hall opening an acoustic impact assessment shall be conducted in agreement with and to the satisfaction of the Licensing Authority which shall include, *inter alia*:
  - An appraisal of the physical structure of the premises and building components in terms of its ability to mitigate internally generated sounds.
  - Specifications for electronic/electrical systems and means to be used as permanent installations for the purposes of producing, reproducing and amplifying music and other sounds associated with the licensed use.
  - Required means to mitigate and prevent adverse noise impact at noise-sensitive premises that includes measure to limit and control internally generated music and other sounds produced, reproduced or amplified by electronic/electrical systems associated with the licensed use.
  - A Noise Management Plan that incorporates external noise sources arising through use of the licensed premises.
2. Ensure that when the Rose Garden banqueting Hall is in use the Noise Prevention and Event Dispersal Policy (Document Reference -RGBH/NPAEDP/01 Dated: 28th April 2020) which has been agreed with Environmental Health is adhered to at all times. This document is subject to annual review and should be updated and/or amended as deemed necessary by the City of Wolverhampton Councils Environmental Health Section.