

Voluntary undertaking- Supplement to Application

NAME OF PREMISES: Purity club

ADDRESS: Pitt Street, Wolverhampton, West Midlands, WV6 0NF

Before signing this document, you should be aware that failure to comply with this undertaking may result in a review of the premises licence and/or enforcement action under the Regulatory Reform (Fire Safety) Order 2005

PUBLIC SAFETY

1) A fire risk assessment will be carried out and the significant findings of the fire risk assessment will be recorded

The safe occupancy of the premises will be restricted to no more than 60 persons (including staff). Suitable management procedures will be adopted to ensure that the safe occupancy is not exceeded. This will feature in the fire risk assessment.
(the above stated figure is for emergency evacuation purposes and may not be a suitable figure for social distancing purposes as required by the Covid-19 regulations)

2) A fire alarm system will be installed and commissioned to British Standard 5839-1.L5 which automatic fire detection provided in areas where a fire could develop undetected and to protect the inner rooms.

A suitable certificate for the fire alarm system will be provided to the Fire Authority before the premises license is operated

3) An emergency lighting system will be installed to comply with British Standard 5266-1. This will include the provision of maintained illuminated fire exit signage at all exit points and coverage within all necessary areas (which may include spots on a box).

A suitable certificate for the emergency lighting system will be provided to the Fire Authority before the premise license is operated.

4) Artificial decorative effects such as plants, flower or shrubs, will be suitably fire retardant or removed from inside the premises.

APPLICANT'S SIGNATURE..

(or representative authorised on behalf of the Premises Licence Holder/applicant)

Date.....

9/10/20

AUTHORISED OFFICER... Neil Aston-Baugh (POSITION) ...*Fire Safety Inspecting Officer (Authorised on behalf of West Midlands Fire Authority)*