

LICENSING ACT 2003**Voluntary undertaking- Supplement to Application - Public Safety**

NAME OF PREMISES: Rose Garden Banqueting Hall

ADDRESS: . 295 Parkfield Road Wolverhampton.WV4 6ED

Before signing this document, you should be aware that failure to comply with this undertaking may result in a review of the premises licence and/or enforcement action under the Regulatory Reform (Fire Safety) Order 2005

PUBLIC SAFETY	
1)	The safe occupancy of the 1 ST floor will be restricted to a maximum capacity of 200 persons. Suitable management procedures will be adopted to ensure that the safe occupancy is not exceeded.
2)	The side, external pathway wall, will be breached to provide unobstructed egress from the front side middle fire exit and a suitable ramp or stepped egress will be provided directly to the car park. The work will be carried out in accordance with the requirements of a suitable building regulations application.
3)	The lobby door through the staircase enclosure at the front side of the building ,will have the fire exit sign removed from the function room side, as this will not be a dedicated fire exit from the ground floor function room.
4)	The above lobby door will be modified on one leaf to ensure that it does not drag on the carpet, preventing it from adequately self-closing.
5)	The decorative artificial foliage/flowers will be suitably fire retardant or removed from the premises.

APPLICANT'S SIGNATURE... 

(or representative authorised on behalf of the Premises Licence Holder/applicant)

Date..... 23/8/21

AUTHORISED OFFICER...Neil Aston-Baugh (POSITION)...Fire Safety Inspecting Officer (Authorised on behalf of West Midlands Fire Authority)