

From: Neil Aston-Baugh <[REDACTED]>
Sent: 22 November 2021 14:56
To: Licensing <Licensing@wolverhampton.gov.uk>
Cc: [REDACTED]
Subject: Fire Authority response to an application for a grant of premises licence, REPRESENTATION

CAUTION: This email originated from outside of the council. Do not click links or open attachments unless you are sure the content is safe.

OFFICIAL

LICENSING ACT 2003

NAME OF PREMISES: AL Sorriso Restaurant

ADDRESS: 18A upper green, Wolverhampton WV6 8QH

I refer to the application for the Grant of a Premises licence made in respect of the above premises.

The premises has been inspected and there are some fire safety issues which could negatively affect the **Public Safety Objective**, if the licence is granted without remedial actions.

- changes of floor level constitute a trip hazard
- The premises requires assessing for the provision of emergency lighting
- The proposed artificial plant may constitute a fire hazard
-
- Staff have not received fire safety training

Consequently, **The Fire Authority hereby makes representation to the application.**

I can inform you that I have been in contact with the applicant and following the discussion, I can offer a voluntary undertaking to the applicant, to modify the proposed use of the premises and/or complete works to the appropriate standard. A copy of the proposed

undertaking is attached.

Should the applicant wish to agree, by signing, dating and returning the undertaking agreement to the Fire Authority, there will be no need for a hearing, providing there are no other relevant representations.

A scan or photograph of the completed document returned by email would be acceptable.

Any voluntary undertaking that the applicant gives to the Fire Authority does not constitute Licence Conditions and should not be treated as such.

You should be aware however that failure to act in accordance with the undertaking may result in the Issue of an enforcement notice under the Regulatory Reform (Fire Safety) Order 2005 and/or a review of the premises licence.

Should you require any further information or clarification, please do not hesitate to contact me.

Regards

Neil Aston-Baugh

Fire Safety Officer -LEEPS Team

Tipton Fire Station
Alexandra Road
Tipton
West Midlands
DY4 7NZ

Tel: [REDACTED] or,

[REDACTED]

Email : [REDACTED]

Team Email: LEEPsTeams.Enquiries@wmfs.net

Fire Safety Admin Email firesafety.admin@wmfs.net

LICENSING ACT 2003***Voluntary undertaking- Supplement to Application*****NAME OF PREMISES:** AL Sorriso Restaurant**ADDRESS:** 18A upper green, Wolverhampton WV6 8QH

Before signing this document, you should be aware that failure to comply with this undertaking may result in a review of the premises licence and/or enforcement action under the Regulatory Reform (Fire Safety) Order 2005

PUBLIC SAFETY
1) If artificial decorative effects (artificial leaves, plants etc) are to be used on the pergola at the approach to the premises, they will be supplied as suitably fire retardant. A certificate of fire retardancy, will be kept, (or other suitable evidence), and will be given to the fire officer upon request.
2) The changes of floor level will be highlighted so that they are conspicuous and suitable signage will be provided to indicate the trip hazards.
3) The premises will be suitably assessed (during the hours of darkness) to check if emergency lighting is required. If required it will be provided in accordance with BS 5266-1.
4) Staff will receive suitable instruction and training on the actions to take in the event of fire which will include hands on fire extinguisher training for appropriate staff.
5) A Fire risk assessment will be undertaken as soon as is reasonably practicable.

APPLICANT'S SIGNATURE...*(or representative authorised on behalf of the Premises Licence Holder/applicant)***APPLICANT'S NAME PRINTED.....****Date.....**

AUTHORISED OFFICER...Neil Aston-Baugh (POSITION)...Fire Safety Inspecting Officer (Authorised on behalf of West Midlands Fire Authority)