

From: Neil Aston-Baugh <[REDACTED]>
Sent: 25 March 2022 13:30
To: Licensing
Cc: [REDACTED]
Subject: Fire Authority representation to a premises licence application.

CAUTION: This email originated from outside of the council. Do not click links or open attachments unless you are sure the content is safe.

OFFICIAL

LICENSING ACT 2003
NAME OF PREMISES: Papa Johns
ADDRESS:268 Penn Road Wolverhampton

I refer to the application for the Grant of a Premises licence made in respect of the above premises. I have visited the premises and there are some fire safety issues which appear to adversely impact upon the Licensing Objective of Public Safety .

- The fire separation between the ground and first floor does not appear to be adequate . The plasterwork looks old, and the ceiling is damaged. This was evident where viewed both in the wash up area and the underside of the staircase to 1st floor (from within the cellar enclosure).
- The fire detection and alarm system did not appear to be connected to the first floor.

Consequently, The Fire Authority hereby makes representation to the application.

The Fire Authority will not remove its representation until it has been provided with evidence that the following work has been suitably carried out:

- Either ensure that the ground floor is separated from the 1st floor by a minimum of 1 hour's fire separating construction **or**
- Make good the existing plaster ceiling by filling in the holes and defects with suitable fire stopping materials to achieve a nominal 30 minutes fire resisting construction and extend the premises fire alarm system to include suitable sounders within the 1st floor residents area/s. Work should be carried out in accordance with BS5839.

Should you require any further information or clarification, please do not hesitate to contact me.

Regards
Neil Aston-Baugh
Fire Safety Officer -LEEPS Team
[REDACTED]