

From: Neil Aston-Baugh [REDACTED]
Sent: 12 September 2022 08:58
To: Licensing
Cc: [REDACTED]
Subject: Fw: Fire Authority representation to a premises licence application. Mediation document recieved
Attachments: signed voluntary undertaking.jpeg

CAUTION: This email originated from outside of the council. Do not click links or open attachments unless you are sure the content is safe.

OFFICIAL

LICENSING ACT 2003
NAME OF PREMISES: Snappy Tomato Pizza
ADDRESS:12 Worcester Street Wolverhampton WV2 4LD

I refer to the representation made by the Fire Authority regarding the application for the Grant of a Premises Licence made in respect of the above premises.
 The applicant has supplied a voluntary undertaking to complete works to the appropriate standards. (As attached).
 The Fire Authority considers this undertaking is sufficient, to show that the Public Safety Objective (as it relates to Fire Safety), will be adequately promoted and confirms that there will be **no need for a hearing, providing there are no other relevant representations.**
 Any voluntary undertaking that the applicant gives to the Fire Authority does not constitute Licence conditions and should not be treated as such.
 You should be aware however that failure to act in accordance with the undertaking may result in the Issue of an enforcement notice under the Regulatory Reform (Fire Safety) Order 2005 and/or a review of the Premises Licence.

Should you require any further information or clarification, please do not hesitate to contact me.

Regards
 Neil Aston-Baugh
 Fire Safety Officer -LEEPS Team

[REDACTED]

OFFICIAL

WEST MIDLANDS FIRE SERVICE

LICENSING ACT 2003

Voluntary undertaking- Supplement to Application.

NAME OF PREMISES: Snappy Tomato Pizza

ADDRESS: 12 Worcester Street Wolverhampton. WV2 4LD

N.B. Before signing this document, you should be aware that failure to comply with this undertaking may result in a review of the premises licence and/or enforcement action under the Regulatory Reform (Fire Safety) Order 2005

PUBLIC SAFETY

1) The upper floors (residential flats) will not be used until the following has taken place.

- The ground floor rear door will be replaced with a fire resisting door (minimum of E30) and fitted with a self-closing device and will not be wedge open or
- The fire escape and staircase will be redesigned so that the fire door opening is not within 1800mm of the staircase.

In either instance the upper floors will not be used until The building control officer (or approved inspector) has stated that the works are satisfactory and that it is safe to occupy.

2) A suitable Fire Risk Assessment will be carried out as soon as is reasonably practicable.

APPLICANT'S SIGNATURE.

print).....

BALDIT SINGH BATIYA

Full Name (please

Date.....

07-09-22

AUTHORISED OFFICER...Neil Aston-Baugh
(POSITION)...Fire Safety Inspecting Officer **authorised on behalf of West Midlands Fire Authority)**

WEST MIDLANDS FIRE SERVICE

LICENSING ACT 2003

Voluntary undertaking- Supplement to Application.

NAME OF PREMISES: Snappy Tomato Pizza

ADDRESS: 12 Worcester Street Wolverhampton. WV2 4LD

N.B. Before signing this document, you should be aware that failure to comply with this undertaking may result in a review of the premises licence and/or enforcement action under the Regulatory Reform (Fire Safety) Order 2005

PUBLIC SAFETY

1) The upper floors (residential flats) will not be used until the following has taken place.

- The ground floor rear door will be replaced with a fire resisting door (minimum of E30) and fitted with a self-closing device and will not be wedge open or
- The fire escape and staircase will be redesigned so that the fire door opening is not within 1800mm of the staircase.

In either instance the upper floors will not be used until The building control officer (or approved inspector) has stated that the works are satisfactory and that it is safe to occupy.

2) A suitable Fire Risk Assessment will be carried out as soon as is reasonably practicable.

APPLICANT'S SIGNATURE.

print).....**BALDIT SINGH BATIYA**

Full Name (please

Date.....**07-09-22**

AUTHORISED OFFICER...Neil Aston-Baugh
(POSITION)...Fire Safety Inspecting Officer **authorised** on behalf of West Midlands Fire Authority)

